



SURAT PERINTAH KERJA

INSTALASI PEMELIHARAAN SARANA PRASARANA

NOMOR :

1022/4/26/L/IPSR

KEPADA :


- | | |
|----------------|-------------|
| 1. Pak Khoirul | 3. Timotius |
| 2. Pak Syaiful | 4. Irawan |

Selesai IPSRS

TANGGAL LAPORAN	NOMOR LAPORAN	PELAKSANAAN	LOKASI
2026-04-23 18:01:29	220/4/26	Kamis, 23 April 2026	Gelatik

NAMA ALAT	MERK	MODEL	NOMOR SERI
Nurse Call	-	-	-

LAPORAN	TINDAKAN	KETERANGAN
nursecall gelatik mati	perbaiki kabel yg lepas	



SPAREPART

- | | |
|----|----|
| 1. | 4. |
| 2. | 5. |
| 3. | 6. |

Mengetahui,

Teknisi Pelaksana

Pak Khoirul

Pak Syaiful

Timotius

Irawan

Penerima Pekerjaan

Riski

bag. IPSRS RSUD SLG

Admin

Alivia Ayu Ninditya

Ka. IPSRS

Nova Dwi Hapsari
NIP. 198403012011012016