



SURAT PERINTAH KERJA

INSTALASI PEMELIHARAAN SARANA PRASARANA

NOMOR :

1045/4/26/A/IPSR

KEPADA :


1. Pak Khoirul
2. Pak Syaiful
3. Fatkhan
4. Heri

Selesai IPSRS

TANGGAL LAPORAN	NOMOR LAPORAN	PELAKSANAAN	LOKASI
2026-04-24 21:08:27	237/4/26	Sabtu, 25 April 2026	Neonatus

NAMA ALAT	MERK	MODEL	NOMOR SERI
AC	McQuay	M5WM10L	AC/B/17

LAPORAN	TINDAKAN	KETERANGAN
AC/B/17 bocor.	Cleaning indoor AC	AC normal



SPAREPART

- 1.
- 2.
- 3.
- 4.
- 5.
- 6.

Mengetahui,

Teknisi Pelaksana

Pak Khoirul

Pak Syaiful

Fatkhan

Heri

Penerima Pekerjaan

Adel

bag. IPSRS RSUD SLG

Admin

Alivia Ayu Ninditya

Ka. IPSRS

Nova Dwi Hapsari
NIP. 198403012011012016