



## SURAT PERINTAH KERJA

### INSTALASI PEMELIHARAAN SARANA PRASARANA

NOMOR :

1047/4/26/A/IPRS

KEPADA :

1. Pak Khoirul
2. Pak Syaiful
3. Fatkhan
4. Heri

**Selesai IPSRS**

TANGGAL LAPORAN	NOMOR LAPORAN	PELAKSANAAN	LOKASI
2026-04-25 07:01:05	241/4/26	Sabtu, 25 April 2026	Parkit
NAMA ALAT	MERK	MODEL	NOMOR SERI
AC	McQuay	M5WM10L	AC/B/29
LAPORAN	TINDAKAN	KETERANGAN	
AC/ B/ 29 KAMAR PARKIT 3 BOCOR PAK	Normalisasi drainase AC	AC Normal setelah perbaikan	



#### SPAREPART

- 1.
- 2.
- 3.
- 4.
- 5.
- 6.

Mengetahui,

Teknisi Pelaksana

Pak Khoirul

Pak Syaiful

Fatkhan

Heri

Penerima Pekerjaan

Novita

bag. IPSRS RSUD SLG

Admin

Alivia Ayu Ninditya

Ka. IPSRS

Nova Dwi Hapsari  
NIP. 198403012011012016