



# SURAT PERINTAH KERJA

## INSTALASI PEMELIHARAAN SARANA PRASARANA

NOMOR :


1075/4/26/A/IPSR

KEPADA :

1. Pak Khoirul
2. Pak Syaiful
3. Ricky
4. Irawan
5. Anam

**Selesai IPSRS**

TANGGAL LAPORAN	NOMOR LAPORAN	PELAKSANAAN	LOKASI
2026-04-28 11:30:59	279/4/26	Selasa, 28 April 2026	Parkit
NAMA ALAT	MERK	MODEL	NOMOR SERI
AC	McQuay	M5WM10L	AC/B/34
LAPORAN	TINDAKAN	KETERANGAN	
AC PARKIT 8 BOCOR KODE AC/B/34	PERBAIKAN DRAIN	normal	



### SPAREPART

- 1.
- 2.
- 3.
- 4.
- 5.
- 6.

Mengetahui,

Teknisi Pelaksana

Pak Khoirul

Pak Syaiful

Ricky

Irawan

Anam

Penerima Pekerjaan

Bu Dwi

Admin

Alivia Ayu Ninditya

bag. IPSRS RSUD SLG  
Ka. IPSRS

Nova Dwi Hapsari  
NIP. 198403012011012016