



SURAT PERINTAH KERJA

INSTALASI PEMELIHARAAN SARANA PRASARANA

NOMOR :

1124/5/26/A/IPSR

KEPADA :

- | | | |
|----------------|---------|------------|
| 1. Pak Khoirul | 3. Anam | 5. Fatkhan |
| 2. Pak Syaiful | 4. Heri | 6. - |

Selesai Pihak Ke-3

| TANGGAL LAPORAN | NOMOR LAPORAN | PELAKSANAAN | LOKASI |
|---------------------|---------------|-------------------|--------|
| 2026-05-04 08:07:18 | 10/5/26 | Senin, 4 Mei 2026 | IBS |

| NAMA ALAT | MERK | MODEL | NOMOR SERI |
|-----------|--------|----------------|------------|
| AC | McQuay | M5MC100H-FIGQA | AC/B1/4 |

| LAPORAN | TINDAKAN | KETERANGAN |
|----------------------------|------------------|------------|
| AC koridor OK tidak dingin | penambahan Freon | |



SPAREPART

- | | |
|----|----|
| 1. | 4. |
| 2. | 5. |
| 3. | 6. |

Mengetahui,

Teknisi Pelaksana

Pak Khoirul

Pak Syaiful

Anam

Heri

Fatkhan

Penerima Pekerjaan

Desi

Admin

Alivia Ayu Ninditya

bag. IPSRS RSUD SLG
Ka. IPSRS

Nova Dwi Hapsari
NIP. 198403012011012016