



# SURAT PERINTAH KERJA

## INSTALASI PEMELIHARAAN SARANA PRASARANA

NOMOR :

1157/5/26/A/IPSR

KEPADA :

1. Pak Khoirul
2. Pak Syaiful
3. Timotius
4. Ricky

**Selesai IPSRS**

TANGGAL LAPORAN	NOMOR LAPORAN	PELAKSANAAN	LOKASI
2026-05-07 14:21:56	54/5/26	Kamis, 7 Mei 2026	Rekam Medis

NAMA ALAT	MERK	MODEL	NOMOR SERI
AC	McQuay	M5WM10L	AC/E/8

LAPORAN	TINDAKAN	KETERANGAN
AC/E/8 bocor	normalisasi drainase	



### SPAREPART

- 1.
- 2.
- 3.
- 4.
- 5.
- 6.

Mengetahui,

Teknisi Pelaksana

Pak Khoirul

Pak Syaiful

Timotius

Ricky

Penerima Pekerjaan

Widya

bag. IPSRS RSUD SLG

Admin

Alivia Ayu Ninditya

Ka. IPSRS

Nova Dwi Hapsari  
NIP. 198403012011012016