



SURAT PERINTAH KERJA

INSTALASI PEMELIHARAAN SARANA PRASARANA

NOMOR :

1180/5/26/A/IPSR

KEPADA :

1. Pak Khoirul
2. Pak Syaiful
3. Fatkhan

Selesai IPSRS

TANGGAL LAPORAN	NOMOR LAPORAN	PELAKSANAAN	LOKASI
2026-05-11 07:38:18	72/5/26	Senin, 11 Mei 2026	Merak

NAMA ALAT	MERK	MODEL	NOMOR SERI
AC	Daikin	FTV25BXV14	AC/C/78

LAPORAN	TINDAKAN	KETERANGAN
ac merak 10 bocor	dilakukan pengecekan dan cleaning indoor beserta drainase	



SPAREPART

- 1.
- 2.
- 3.
- 4.
- 5.
- 6.

Mengetahui,

Teknisi Pelaksana

Pak Khoirul

Pak Syaiful

Fatkhan

Penerima Pekerjaan

Binti

Admin

Alivia Ayu Ninditya

bag. IPSRS RSUD SLG
Ka. IPSRS

Nova Dwi Hapsari
NIP. 198403012011012016