



SURAT PERINTAH KERJA

INSTALASI PEMELIHARAAN SARANA PRASARANA

NOMOR :

1217/5/26/A/IPRS

KEPADA :

1. Pak Khoirul
2. Pak Syaiful
3. Fatkhan
4. Ricky

Selesai IPSRS

TANGGAL LAPORAN	NOMOR LAPORAN	PELAKSANAAN	LOKASI
2026-05-13 08:08:45	112/5/26	Rabu, 13 Mei 2026	Laboratorium

NAMA ALAT	MERK	MODEL	NOMOR SERI
AC	Daikin	FTV50CXV14	AC/B/81

LAPORAN	TINDAKAN	KETERANGAN
AC/B/81 tidak dingin	cek ampere (8A), cek suhu, pembersihan fan dan filter	



SPAREPART

- 1.
- 2.
- 3.
- 4.
- 5.
- 6.

Mengetahui,

Teknisi Pelaksana

Pak Khoirul

Pak Syaiful

Fatkhan

Ricky

Penerima Pekerjaan

Mbak Nita

bag. IPSRS RSUD SLG

Admin

Alivia Ayu Ninditya

Ka. IPSRS

Nova Dwi Hapsari
NIP. 198403012011012016