



SURAT PERINTAH KERJA

INSTALASI PEMELIHARAAN SARANA PRASARANA

NOMOR :

1309/5/26/A/IPSR

KEPADA :

1. Pak Khoirul
2. Pak Syaiful
3. Anam
4. Ricky

Selesai IPSRS

TANGGAL LAPORAN	NOMOR LAPORAN	PELAKSANAAN	LOKASI
2026-05-21 10:01:54	211/5/26	Kamis, 21 Mei 2026	Radiologi

NAMA ALAT	MERK	MODEL	NOMOR SERI
AC	McQuay	M5WM10L	AC/B/72

LAPORAN	TINDAKAN	KETERANGAN
AC/B/72 (ruang panoramic) bocor. Minta di cek nanti setelah pelayanan	normalisasi drainase, uji coba drainase dengan air(lancar)	



SPAREPART

- 1.
- 2.
- 3.
- 4.
- 5.
- 6.

Mengetahui,

Teknisi Pelaksana

Pak Khoirul

Pak Syaiful

Anam

Ricky

Penerima Pekerjaan

Mbak Devi

bag. IPSRS RSUD SLG

Admin

Alivia Ayu Ninditya

Ka. IPSRS

Nova Dwi Hapsari
NIP. 198403012011012016