



SURAT PERINTAH KERJA

INSTALASI PEMELIHARAAN SARANA PRASARANA

NOMOR :

1347/5/26/L/IPSRS

KEPADA :


1. Pak Khoirul
2. Pak Syaiful
3. Anam
4. Ricky

Selesai IPSRS

TANGGAL LAPORAN	NOMOR LAPORAN	PELAKSANAAN	LOKASI
2026-05-29 13:17:36	270/5/26	Jum'at, 29 Mei 2026	Klinik Jantung

NAMA ALAT	MERK	MODEL	NOMOR SERI
Lampu Penerangan	Philips	-	-

LAPORAN	TINDAKAN	KETERANGAN
lampu di lorong poli Lt.1 mati 1 kotak	penggantian lampu	lampu normal setelah di ganti



SPAREPART

1. lampu TL LED T8/10 watt 3 buah
- 2.
- 3.

- 4.
- 5.
- 6.

Mengetahui,

Teknisi Pelaksana

Pak Khoirul

Pak Syaiful

Anam

Ricky

Penerima Pekerjaan

Azizah

bag. IPSRS RSUD SLG

Admin

Alivia Ayu Ninditya

Ka. IPSRS

Nova Dwi Hapsari
NIP. 198403012011012016