



# SURAT PERINTAH KERJA

## INSTALASI PEMELIHARAAN SARANA PRASARANA

NOMOR :

159/1/26/A/IPSR

KEPADA :


1. Pak Khoirul
2. Pak Syaiful
3. Timotius
4. Fatkhan
5. Anam

**Selesai IPSRS**

TANGGAL LAPORAN	NOMOR LAPORAN	PELAKSANAAN	LOKASI
2026-01-14 13:10:56	178/1/26	Kamis, 15 Januari 2026	Parkit

NAMA ALAT	MERK	MODEL	NOMOR SERI
AC	McQuay	M5WM10L	AC/B/29

LAPORAN	TINDAKAN	KETERANGAN
ac/b/29 ruang pasien 3 bocor	AC normal setelah dinormalisasi drainase	



### SPAREPART

- 1.
- 2.
- 3.
- 4.
- 5.
- 6.

Mengetahui,

Teknisi Pelaksana

Pak Khoirul

Pak Syaiful

Timotius

Fatkhan

Anam

Penerima Pekerjaan

Bu Dwi

Admin

Alivia Ayu Ninditya

bag. IPSRS RSUD SLG  
Ka. IPSRS

Nova Dwi Hapsari  
NIP. 198403012011012016