



## SURAT PERINTAH KERJA

### INSTALASI PEMELIHARAAN SARANA PRASARANA

NOMOR :

2/1/26/A/IPSRS

KEPADA :

1. Pak Khoirul
2. Pak Syaiful
3. Fatkhan
4. Ricky

**Selesai IPSRS**

TANGGAL LAPORAN	NOMOR LAPORAN	PELAKSANAAN	LOKASI
2026-01-01 13:10:51	1/1/26	Jum'at, 2 Januari 2026	ICVCU
NAMA ALAT	MERK	MODEL	NOMOR SERI
AC	McQuay	M5WM10L	AC/B/51
LAPORAN	TINDAKAN	KETERANGAN	
AC bed 1 bocor (ada pasien)	normalisasi drainase	kondisi normal	



#### SPAREPART

- 1.
- 2.
- 3.
- 4.
- 5.
- 6.

Mengetahui,

Teknisi Pelaksana

Pak Khoirul

Pak Syaiful

Fatkhan

Ricky

Penerima Pekerjaan

Mbak Helga

bag. IPSRS RSUD SLG

Admin

Alivia Ayu Ninditya

Ka. IPSRS

Nova Dwi Hapsari  
NIP. 198403012011012016