



SURAT PERINTAH KERJA

INSTALASI PEMELIHARAAN SARANA PRASARANA

NOMOR :

242/1/26/A/IPSR

KEPADA :

1. Pak Khoirul
2. Pak Syaiful
3. Fatkhan
4. Adji
5. Ricky

Selesai IPSRS

TANGGAL LAPORAN	NOMOR LAPORAN	PELAKSANAAN	LOKASI
2026-01-26 09:46:06	279/1/26	Senin, 26 Januari 2026	Radiologi

NAMA ALAT	MERK	MODEL	NOMOR SERI
AC	McQuay	M5WM20P	AC/B/78

LAPORAN	TINDAKAN	KETERANGAN
Ac ruang foto 1 (AC/C/78) bocor	drainase AC buntu	menormalisasi drainase AC



SPAREPART

- 1.
- 2.
- 3.
- 4.
- 5.
- 6.

Mengetahui,

Teknisi Pelaksana

Pak Khoirul

Pak Syaiful

Fatkhan

Adji

Ricky

Penerima Pekerjaan

Mbak Era

Admin

Alivia Ayu Ninditya

bag. IPSRS RSUD SLG
Ka. IPSRS

Nova Dwi Hapsari
NIP. 198403012011012016