



SURAT PERINTAH KERJA

INSTALASI PEMELIHARAAN SARANA PRASARANA

NOMOR :

246/1/26/E/IPSR

KEPADA :			Selesai IPSRS
1. Pak Khoirul	3. Aris	5. Jesisca	
2. Pak Syaiful	4. Dika		

TANGGAL LAPORAN	NOMOR LAPORAN	PELAKSANAAN	LOKASI
2026-01-26 15:06:46	283/1/26	Selasa, 27 Januari 2026	IBS

NAMA ALAT	MERK	MODEL	NOMOR SERI
O2 Sentral	-	-	-

LAPORAN	TINDAKAN	KETERANGAN
Oksigen Central Ok 1 bocor	ganti selang yang bocor	



SPAREPART

1. Selang PU 5x8 mm	30 cm	4.
2.		5.
3.		6.

Mengetahui,

Teknisi Pelaksana

Bu Nova

Aris

Dika

Jesisca

Penerima Pekerjaan

Ardi

bag. IPSRS RSUD SLG

Admin

Alivia Ayu Ninditya

Ka. IPSRS

Nova Dwi Hapsari
NIP. 198403012011012016