



SURAT PERINTAH KERJA

INSTALASI PEMELIHARAAN SARANA PRASARANA

NOMOR :

471/2/26/A/IPSR

KEPADA :


1. Pak Khoirul
2. Pak Syaiful
3. Fatkhan
4. Ricky

Selesai IPSRS

TANGGAL LAPORAN	NOMOR LAPORAN	PELAKSANAAN	LOKASI
2026-02-15 18:53:46	138/2/26	Minggu, 15 Februari 2026	Laundry

NAMA ALAT	MERK	MODEL	NOMOR SERI
AC	Panasonic	CS-YN9WKJ	AC/E/27

LAPORAN	TINDAKAN	KETERANGAN
ac/e/27 drainase bocor	AC bocor pada drainase avur	normalisasi drainase



SPAREPART

- 1.
- 2.
- 3.
- 4.
- 5.
- 6.

Mengetahui,

Teknisi Pelaksana

Pak Khoirul

Pak Syaiful

Fatkhan

Ricky

Penerima Pekerjaan

Fandy

bag. IPSRS RSUD SLG

Admin

Alivia Ayu Ninditya

Ka. IPSRS

Nova Dwi Hapsari
NIP. 198403012011012016