



SURAT PERINTAH KERJA

INSTALASI PEMELIHARAAN SARANA PRASARANA

NOMOR :

610/3/26/A/IPSR

KEPADA :



- | | | |
|----------------|----------|-----------|
| 1. Pak Khoirul | 3. Ricky | 5. Irawan |
| 2. Pak Syaiful | 4. Heri | 6. Adji |

Selesai IPSRS

TANGGAL LAPORAN	NOMOR LAPORAN	PELAKSANAAN	LOKASI
2026-03-09 11:16:59	87/3/26	Senin, 9 Maret 2026	IBS

NAMA ALAT	MERK	MODEL	NOMOR SERI
AC	McQuay	M5MC100H-FIGQA	AC/B1/1

LAPORAN	TINDAKAN	KETERANGAN
Ada suara di Hepa filter OK 1	melakukan pembersihan pada hepafilter dan housing hepafilter	



SPAREPART

- | | |
|----|----|
| 1. | 4. |
| 2. | 5. |
| 3. | 6. |

Mengetahui,

Teknisi Pelaksana

Pak Khoirul

Pak Syaiful

Ricky

Heri

Irawan

Adji

Penerima Pekerjaan

Mbak Desi

bag. IPSRS RSUD SLG

Admin

Alivia Ayu Ninditya

Ka. IPSRS

Nova Dwi Hapsari
NIP. 198403012011012016