



SURAT PERINTAH KERJA

INSTALASI PEMELIHARAAN SARANA PRASARANA

NOMOR :

641/3/26/A/IPSR

KEPADA :


- | | | |
|----------------|------------|----------|
| 1. Pak Khoirul | 3. Anam | 5. Heri |
| 2. Pak Syaiful | 4. Fatkhan | 6. Ricky |

Selesai IPSRS

TANGGAL LAPORAN	NOMOR LAPORAN	PELAKSANAAN	LOKASI
2026-03-05 09:39:19	48/3/26	Selasa, 10 Maret 2026	Perkutut

NAMA ALAT	MERK	MODEL	NOMOR SERI
AC	McQuay	M5WM10L	AC/D/7

LAPORAN	TINDAKAN	KETERANGAN
AC/D/7 (perkutut 9) bocor	dilakukan oengecekan dan cleaning indoor beserta drainasnya	



SPAREPART

- | | |
|----|----|
| 1. | 4. |
| 2. | 5. |
| 3. | 6. |

Mengetahui,

Teknisi Pelaksana

Pak Khoirul

Pak Syaiful

Anam

Fatkhan

Heri

Ricky

Penerima Pekerjaan

Nafik

bag. IPSRS RSUD SLG

Admin

Alivia Ayu Ninditya

Ka. IPSRS

Nova Dwi Hapsari
NIP. 198403012011012016