



# SURAT PERINTAH KERJA

## INSTALASI PEMELIHARAAN SARANA PRASARANA

NOMOR :

670/3/26/A/IPSR

KEPADA :


- |                |             |
|----------------|-------------|
| 1. Pak Khoirul | 3. Fatkhan  |
| 2. Pak Syaiful | 4. Timotius |

**Selesai IPSRS**

TANGGAL LAPORAN	NOMOR LAPORAN	PELAKSANAAN	LOKASI
2026-03-11 10:03:13	124/3/26	Rabu, 11 Maret 2026	Gizi

NAMA ALAT	MERK	MODEL	NOMOR SERI
AC			freser 2

LAPORAN	TINDAKAN	KETERANGAN
SUHU FREEZER TIDAK DINGIN, MENTOK DI SUHU 3 DERAJAT CELCIUS	memasang pembatas dinding	



### SPAREPART

- |    |    |
|----|----|
| 1. | 4. |
| 2. | 5. |
| 3. | 6. |

Mengetahui,

Teknisi Pelaksana

Pak Khoirul

Pak Syaiful

Fatkhan

Timotius

Penerima Pekerjaan

Udin

bag. IPSRS RSUD SLG

Admin

Alivia Ayu Ninditya

Ka. IPSRS

Nova Dwi Hapsari  
NIP. 198403012011012016