



# SURAT PERINTAH KERJA

## INSTALASI PEMELIHARAAN SARANA PRASARANA

NOMOR :

703/3/26/A/IPSRs

KEPADA :

1. Pak Khoirul
2. Pak Syaiful
3. Anam
4. Adji
5. Timotius

**Selesai IPSRS**

TANGGAL LAPORAN	NOMOR LAPORAN	PELAKSANAAN	LOKASI
2026-03-16 08:26:11	160/3/26	Senin, 16 Maret 2026	Perkutut

NAMA ALAT	MERK	MODEL	NOMOR SERI
AC	McQuay	M5WM10L	AC/D/11

LAPORAN	TINDAKAN	KETERANGAN
AC perkutut kamar 2	mereset ulangremot AC, dan filter indoor kotor	



### SPAREPART

- 1.
- 2.
- 3.
- 4.
- 5.
- 6.

Mengetahui,

Teknisi Pelaksana

Pak Khoirul

Pak Syaiful

Anam

Adji

Timotius

Penerima Pekerjaan

Mas Nafik

Admin

Alivia Ayu Ninditya

bag. IPSRS RSUD SLG  
Ka. IPSRS

Nova Dwi Hapsari  
NIP. 198403012011012016