



## SURAT PERINTAH KERJA

### INSTALASI PEMELIHARAAN SARANA PRASARANA

NOMOR :

709/3/26/A/IPSR

KEPADA :

- |                |           |      |
|----------------|-----------|------|
| 1. Pak Khoirul | 3. Ricky  | 5. - |
| 2. Pak Syaiful | 4. Irawan | 6. - |

**Selesai Pihak Ke-3**

TANGGAL LAPORAN	NOMOR LAPORAN	PELAKSANAAN	LOKASI
2026-03-16 12:11:16	167/3/26	Selasa, 17 Maret 2026	IBS

NAMA ALAT	MERK	MODEL	NOMOR SERI
AC	Daikin	RCN150HY14	AC/B1/3

LAPORAN	TINDAKAN	KETERANGAN
AC OK 5 & 6 PANAS	penggantian fanbelt	AC normal dan dingin



#### SPAREPART

- |            |   |    |
|------------|---|----|
| 1. fanbelt | 1 | 4. |
| 2.         |   | 5. |
| 3.         |   | 6. |

Mengetahui,

Teknisi Pelaksana

Pak Khoirul

Pak Syaiful

Ricky

Irawan

Penerima Pekerjaan

Desi

bag. IPSRS RSUD SLG

Admin

Alivia Ayu Ninditya

Ka. IPSRS

Nova Dwi Hapsari  
NIP. 198403012011012016