



SURAT PERINTAH KERJA
INSTALASI PEMELIHARAAN SARANA PRASARANA

NOMOR :

751/3/26/A/IPSR

KEPADA :

- | | | |
|----------------|-------------|---------|
| 1. Pak Khoirul | 3. Timotius | 5. Anam |
| 2. Pak Syaiful | 4. Adji | |

Selesai IPSRS

TANGGAL LAPORAN	NOMOR LAPORAN	PELAKSANAAN	LOKASI
2026-03-27 09:56:35	204/3/26	Senin, 30 Maret 2026	Gizi

NAMA ALAT	MERK	MODEL	NOMOR SERI
AC	McQuay	M5WM10L	AC/E/6

LAPORAN	TINDAKAN	KETERANGAN
AC KODE E 6 BOCOR (AC RUANG KAINS)	normalisasi drainase	



SPAREPART

- | | |
|----|----|
| 1. | 4. |
| 2. | 5. |
| 3. | 6. |

Mengetahui,

Teknisi Pelaksana

Pak Khoirul

Pak Syaiful

Timotius

Adji

Anam

Penerima Pekerjaan

Navyta

Admin

Alivia Ayu Ninditya

bag. IPSRS RSUD SLG
Ka. IPSRS

Nova Dwi Hapsari
NIP. 198403012011012016