



## SURAT PERINTAH KERJA

### INSTALASI PEMELIHARAAN SARANA PRASARANA

NOMOR :

765/3/26/A/IPSR

KEPADA :

- |                |             |         |
|----------------|-------------|---------|
| 1. Pak Khoirul | 3. Timotius | 5. Adji |
| 2. Pak Syaiful | 4. Anam     |         |

**Selesai IPSRS**

TANGGAL LAPORAN	NOMOR LAPORAN	PELAKSANAAN	LOKASI
2026-03-30 12:52:43	219/3/26	Selasa, 31 Maret 2026	IT

NAMA ALAT	MERK	MODEL	NOMOR SERI
AC	McQuay	M5WM10L	AC/A/79

LAPORAN	TINDAKAN	KETERANGAN
ac ruang IT tidak dingin	ac normal saat di cek ampere	



#### SPAREPART

- |    |    |
|----|----|
| 1. | 4. |
| 2. | 5. |
| 3. | 6. |

Mengetahui,

Teknisi Pelaksana

Pak Khoirul

Pak Syaiful

Timotius

Anam

Adji

Penerima Pekerjaan

Eka

Admin

Alivia Ayu Ninditya

bag. IPSRS RSUD SLG  
Ka. IPSRS

Nova Dwi Hapsari  
NIP. 198403012011012016