



SURAT PERINTAH KERJA

INSTALASI PEMELIHARAAN SARANA PRASARANA

NOMOR :

781/4/26/A/IPSRS

KEPADA :


1. Pak Khoirul
2. Pak Syaiful
3. Timotius
4. Heri

Selesai IPSRS

TANGGAL LAPORAN	NOMOR LAPORAN	PELAKSANAAN	LOKASI
2026-03-31 11:31:48	232/3/26	Rabu, 1 April 2026	Gizi

NAMA ALAT	MERK	MODEL	NOMOR SERI
AC	Array	Array	AC/E/6

LAPORAN	TINDAKAN	KETERANGAN
ac ruang kains bocor lagi. kode e 6	perbaiki harmaplek yg basah yg mengakibatkan netes air	



SPAREPART

- 1.
- 2.
- 3.
- 4.
- 5.
- 6.

Mengetahui,

Teknisi Pelaksana

Pak Khoirul

Pak Syaiful

Timotius

Heri

Penerima Pekerjaan

Pak Nonot

bag. IPSRS RSUD SLG

Admin

Alivia Ayu Ninditya

Ka. IPSRS

Nova Dwi Hapsari
NIP. 198403012011012016