



# SURAT PERINTAH KERJA

## INSTALASI PEMELIHARAAN SARANA PRASARANA

NOMOR :

781/4/26/A/IPSR

KEPADA :


- |                |             |
|----------------|-------------|
| 1. Pak Khoirul | 3. Timotius |
| 2. Pak Syaiful | 4. Heri     |

**Selesai IPSRS**

TANGGAL LAPORAN	NOMOR LAPORAN	PELAKSANAAN	LOKASI
2026-03-31 11:31:48	232/3/26	Rabu, 1 April 2026	Gizi

NAMA ALAT	MERK	MODEL	NOMOR SERI
AC	McQuay	M5WM10L	AC/E/6

LAPORAN	TINDAKAN	KETERANGAN
ac ruang kains bocor lagi. kode e 6	perbaiki harmaplek yg basah yg mengakibatkan netes air	



### SPAREPART

- |    |    |
|----|----|
| 1. | 4. |
| 2. | 5. |
| 3. | 6. |

Mengetahui,

Teknisi Pelaksana

Pak Khoirul

Pak Syaiful

Timotius

Heri

Penerima Pekerjaan

Pak Nonot

bag. IPSRS RSUD SLG

Admin

Alivia Ayu Ninditya

Ka. IPSRS

Nova Dwi Hapsari  
NIP. 198403012011012016