



SURAT PERINTAH KERJA

INSTALASI PEMELIHARAAN SARANA PRASARANA

NOMOR :

794/4/26/A/IPSR

KEPADA :

- | | |
|----------------|----------|
| 1. Pak Khoirul | 3. Anam |
| 2. Pak Syaiful | 4. Ricky |

Selesai IPSRS

TANGGAL LAPORAN	NOMOR LAPORAN	PELAKSANAAN	LOKASI
2026-04-02 08:49:30	8/4/26	Senin, 6 April 2026	Farmasi Rawat Jalan Lt. 1

NAMA ALAT	MERK	MODEL	NOMOR SERI
AC	Panasonic	CS-YN5WKJ	AC/A/319

LAPORAN	TINDAKAN	KETERANGAN
AC/A/319 tidak dingin	pengecekan unit indoor	



SPAREPART

- | | |
|----|----|
| 1. | 4. |
| 2. | 5. |
| 3. | 6. |

Mengetahui,

Teknisi Pelaksana

Pak Khoirul

Pak Syaiful

Anam

Ricky

Penerima Pekerjaan

Bu Intan

bag. IPSRS RSUD SLG

Admin

Alivia Ayu Ninditya

Ka. IPSRS

Nova Dwi Hapsari
NIP. 198403012011012016