



# SURAT PERINTAH KERJA

## INSTALASI PEMELIHARAAN SARANA PRASARANA

NOMOR :

800/4/26/A/IPSRs

KEPADA :

- |                |          |           |
|----------------|----------|-----------|
| 1. Pak Khoirul | 3. Anam  | 5. Irawan |
| 2. Pak Syaiful | 4. Ricky |           |

**Selesai IPSRS**

TANGGAL LAPORAN	NOMOR LAPORAN	PELAKSANAAN	LOKASI
2026-04-02 07:12:49	7/4/26	Senin, 6 April 2026	Parkit

NAMA ALAT	MERK	MODEL	NOMOR SERI
AC	McQuay	M5WM10P	AC/B/32

LAPORAN	TINDAKAN	KETERANGAN
AC ruang parkit bocor kode AC = AC/B/32	cleaning ac	



### SPAREPART

- |    |    |
|----|----|
| 1. | 4. |
| 2. | 5. |
| 3. | 6. |

Mengetahui,

Teknisi Pelaksana

Pak Khoirul

Pak Syaiful

Anam

Ricky

Irawan

Penerima Pekerjaan

Novika

Admin

Alivia Ayu Ninditya

bag. IPSRS RSUD SLG  
Ka. IPSRS

Nova Dwi Hapsari  
NIP. 198403012011012016