



SURAT PERINTAH KERJA

INSTALASI PEMELIHARAAN SARANA PRASARANA

NOMOR :

855/4/26/A/IPSRs

KEPADA :

- | | | |
|----------------|----------|---------|
| 1. Pak Khoirul | 3. Heri | 5. Anam |
| 2. Pak Syaiful | 4. Ricky | |

Selesai IPSRS

TANGGAL LAPORAN	NOMOR LAPORAN	PELAKSANAAN	LOKASI
2026-04-10 09:02:51	88/4/26	Jum'at, 10 April 2026	Radiologi

NAMA ALAT	MERK	MODEL	NOMOR SERI
AC	McQuay	M5WM10L	AC/B/75

LAPORAN	TINDAKAN	KETERANGAN
AC/B/75 bocor lagi	normalisasi drainase	



SPAREPART

- | | |
|----|----|
| 1. | 4. |
| 2. | 5. |
| 3. | 6. |

Mengetahui,

Teknisi Pelaksana

Pak Khoirul

Pak Syaiful

Heri

Ricky

Anam

Penerima Pekerjaan

Era

Admin

Alivia Ayu Ninditya

bag. IPSRS RSUD SLG
Ka. IPSRS

Nova Dwi Hapsari
NIP. 198403012011012016