



SURAT PERINTAH KERJA

INSTALASI PEMELIHARAAN SARANA PRASARANA

NOMOR :

873/4/26/A/IPSR

KEPADA :


1. Pak Khoirul
2. Pak Syaiful
3. Adji
4. Anam
5. Fatkhan

Selesai IPSRS

| TANGGAL LAPORAN | NOMOR LAPORAN | PELAKSANAAN | LOKASI |
|---------------------|---------------|----------------------|--------|
| 2026-04-09 06:49:31 | 71/4/26 | Senin, 13 April 2026 | Parkit |

| NAMA ALAT | MERK | MODEL | NOMOR SERI |
|-----------|--------|---------|------------|
| AC | McQuay | M5WM10L | AC/B/29 |

| LAPORAN | TINDAKAN | KETERANGAN |
|--------------|--|------------|
| AC B29 BOCOR | dilakukan pengecekan dan cleaning drainase | |



SPAREPART

- 1.
- 2.
- 3.
- 4.
- 5.
- 6.

Mengetahui,

Teknisi Pelaksana

Pak Khoirul

Pak Syaiful

Adji

Anam

Fatkhan

Penerima Pekerjaan

Bu Dwi Setyowati

Admin

Alivia Ayu Ninditya

bag. IPSRS RSUD SLG
Ka. IPSRS

Nova Dwi Hapsari
NIP. 198403012011012016