



# SURAT PERINTAH KERJA

## INSTALASI PEMELIHARAAN SARANA PRASARANA

NOMOR :

882/4/26/A/IPRS

KEPADA :

1. Pak Khoirul
2. Pak Syaiful
3. Fatkhan
4. Anam
5. Ricky

**Selesai IPSRS**

TANGGAL LAPORAN	NOMOR LAPORAN	PELAKSANAAN	LOKASI
2026-04-13 19:47:54	111/4/26	Selasa, 14 April 2026	Parkit

NAMA ALAT	MERK	MODEL	NOMOR SERI
AC	McQuay	M5WM10L	AC/B/29

LAPORAN	TINDAKAN	KETERANGAN
AC KAMAR 3 ( AC/B/29 ) BOCOR	pengecekan unit indoor normalisasi drainase	



### SPAREPART

- 1.
- 2.
- 3.
- 4.
- 5.
- 6.

Mengetahui,

Teknisi Pelaksana

Pak Khoirul

Pak Syaiful

Fatkhan

Anam

Ricky

Penerima Pekerjaan

Dwi

Admin

Alivia Ayu Ninditya

bag. IPSRS RSUD SLG  
Ka. IPSRS

Nova Dwi Hapsari  
NIP. 198403012011012016