



# SURAT PERINTAH KERJA

## INSTALASI PEMELIHARAAN SARANA PRASARANA

NOMOR :

899/4/26/A/IPSRs

KEPADA :

1. Pak Khoirul
2. Pak Syaiful
3. Anam
4. Ricky
5. -
6. -

**Proses Pihak Ke-3**

TANGGAL LAPORAN	NOMOR LAPORAN	PELAKSANAAN	LOKASI
2026-04-15 08:44:20	126/4/26	Kamis, 16 April 2026	PICU
NAMA ALAT	MERK	MODEL	NOMOR SERI
AC	Array	Array	AC/b/50
LAPORAN	TINDAKAN	KETERANGAN	
AC/B/50 (ampere 1,8 dari 3,84)	pengecekan indoor ampere kurang		



**SPAREPART**

-

Mengetahui,

Teknisi Pelaksana

Pak Khoirul

Pak Syaiful

Anam

Ricky

Penerima Pekerjaan

Bu Silvi

bag. IPSRS RSUD SLG

Admin

Alivia Ayu Ninditya

Ka. IPSRS

Nova Dwi Hapsari  
NIP. 198403012011012016