



SURAT PERINTAH KERJA

INSTALASI PEMELIHARAAN SARANA PRASARANA

NOMOR :

915/4/26/A/IPSR

KEPADA :



1. Pak Khoirul
2. Pak Syaiful
3. Timotius
4. Ricky
5. Anam

Selesai IPSRS

TANGGAL LAPORAN	NOMOR LAPORAN	PELAKSANAAN	LOKASI
2026-04-17 10:08:43	162/4/26	Jum'at, 17 April 2026	Farmasi Rawat Jalan Lt. 2

NAMA ALAT	MERK	MODEL	NOMOR SERI
AC	McQuay	M5WM10L	AC/B/54

LAPORAN	TINDAKAN	KETERANGAN
AC/A/54 (farmasi Rawat jalan Lt.2) bocor	normalisasi darinase	



SPAREPART

- 1.
- 2.
- 3.
- 4.
- 5.
- 6.

Mengetahui,

Teknisi Pelaksana

Pak Khoirul

Pak Syaiful

Timotius

Ricky

Anam

Penerima Pekerjaan

Bu Umi

Admin

Alivia Ayu Ninditya

bag. IPSRS RSUD SLG
Ka. IPSRS

Nova Dwi Hapsari
NIP. 198403012011012016