



SURAT PERINTAH KERJA

INSTALASI PEMELIHARAAN SARANA PRASARANA

NOMOR :

919/4/26/A/IPSR

KEPADA :

1. Pak Khoirul
2. Pak Syaiful
3. Timotius
4. Anam

Selesai IPSRS

TANGGAL LAPORAN	NOMOR LAPORAN	PELAKSANAAN	LOKASI
2026-04-17 08:49:52	156/4/26	Jum'at, 17 April 2026	Kasuari

NAMA ALAT	MERK	MODEL	NOMOR SERI
AC	Daikin	FTV25BXV14	AC/C/83

LAPORAN	TINDAKAN	KETERANGAN
AC kamar 9 bocor	NORMAL	



SPAREPART

- 1.
- 2.
- 3.
- 4.
- 5.
- 6.

Mengetahui,

Teknisi Pelaksana

Pak Khoirul

Pak Syaiful

Timotius

Anam

Penerima Pekerjaan

Bu Arisa

bag. IPSRS RSUD SLG

Admin

Alivia Ayu Ninditya

Ka. IPSRS

Nova Dwi Hapsari
NIP. 198403012011012016