



# SURAT PERINTAH KERJA

## INSTALASI PEMELIHARAAN SARANA PRASARANA

NOMOR :

996/4/26/A/IPSRs

KEPADA :

- |                |          |         |
|----------------|----------|---------|
| 1. Pak Khoirul | 3. Adji  | 5. Anam |
| 2. Pak Syaiful | 4. Ricky |         |

**Selesai IPSRS**

TANGGAL LAPORAN	NOMOR LAPORAN	PELAKSANAAN	LOKASI
2026-04-21 12:12:11	190/4/26	Rabu, 22 April 2026	Parkit

NAMA ALAT	MERK	MODEL	NOMOR SERI
AC			AC/B/302 DAN AC/B/35

LAPORAN	TINDAKAN	KETERANGAN
AC NURSE STATION BOCOR AC/B/302 DAN AC KAMAR PARKIT 5 BOCOR JUGA AC/B/35 (PX KEGERAHAN PAK)	cleaning dan normalisasi drainase	



### SPAREPART

- |    |    |
|----|----|
| 1. | 4. |
| 2. | 5. |
| 3. | 6. |

Mengetahui,

Teknisi Pelaksana

Pak Khoirul

Pak Syaiful

Adji

Ricky

Anam

Penerima Pekerjaan

Siti Mubarakah

Admin

Alivia Ayu Ninditya

bag. IPSRS RSUD SLG  
Ka. IPSRS

Nova Dwi Hapsari  
NIP. 198403012011012016